PROJECT TITLE


313 B DAYCARE RENOVATION

PROJECT ADDRESS

DEPARTMENT OF VETERANS AFFAIRS VA MEDICAL CENTER MARTINSBURG, WV







ARCHITECTS

Drawing Title
Cover Sheet Approved: Project Director

Project Title
Building 313B - Daycare Renovation 613-13-126 Building Number 313B Drawing Number VAMC, Martinsburg, WV


CJZ


MAS


04-23-2014


Office of Construction and Facilities Management


Department of Veterans Affairs


















































































































FIRE ALARM / MNS INPUT-OUTPUT MATRIX FIRE ALARM GENERAL NOTES SPRINKLER GENERAL NOTES LEGEND (ALL SYMBOLS MAY NOT BE UTILIZED ON EVERY SHEET) SPRINKLER SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH **HEAT DETECTOR** APPLICABLE CODES AND STANDARDS: THE PROJECT NFPA 13, UFC 3-600-01 AND UFC 3-600-10N. INSTALLATION MUST SATISFY THE FOLLOWING CODES AND STANDARDS USING THE MOST STRINGENT REQUIREMENT WHEN 2. PROVIDE QUICK RESPONSE WET-PIPE SPRINKLERS IN ALL AREAS. COMBINATION SPEAKER/STROBE - WALL MOUNTED THERE IS A CONFLICT BETWEEN THEM: SPRINKLERS FOR GENERAL AREAS SHALL BE 165 DEG F RATED QUICK RESPONSE TYPE. MAXIMUM COVERAGE AREA PER NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) SPEAKER - WALL MOUNTED, WEATHERPROOF SPRINKLER IN LIGHT HAZARD AREAS SHALL NOT EXCEED 225 SQ NFPA 13, INSTALLATION OF SPRINKLER SYSTEMS (2010 EDITION) FT AND FOR ORDINARY HAZARD AREAS 130 SQ FT. NFPA 70, NATIONAL ELECTRIC CODE (2008 EDITION) COMBINATION SPEAKER/STROBE - CEILING MOUNTED 3. THE MODIFICATIONS TO THE SPRINKLER SYSTEM SHALL BE NFPA 72, NATIONAL FIRE ALARM AND SIGNALING CODE (2010 HYDRAULICALLY CALCULATED FOR LIGHT HAZARD OCCUPANCY S SPEAKER - CEILING MOUNTED UNLESS OTHERWISE INDICATED. CONTRACTOR SHALL UTILIZE A NFPA 101, LIFE SAFETY CODE (2009 EDITION) REMOTE DESIGN AREA OF 3000 SQ.FT, HOSE STREAM UPON ANY REPROGRAMMING OF THE FIRE ALARM CONTROL FIRE ALARM PULL STATION. ALLOWANCES OF 250 GPM, AND A DURATION OF 60 MINUTES. PANEL, CONTRACTOR SHALL ENSURE THAT THE SEQUENCE OF SPRINKLERS IN STORAGE SPACES, MECHANICAL SPACES AND OPERATIONS HAS BEEN MAINTAINED. OTHER ORDINARY HAZARD GROUP 1 SPACES SHALL BE FIRE ALARM STROBE HYDRAULICALLY DESIGNED TO PROVIDE 0.15 GPM/SQ FT OVER THE **ABBREVIATIONS** AFFILIATED REMOTE 3000 SQ FT PLUS A 500 GPM HOSE STREAM FIRE ALARM INPUT DUCT SMOKE DETECTOR ALLOWANCE IN ACCORDANCE WITH UFC 3-600-01. QUICK RESPONSE SPRINKLER DESIGN AREA REDUCTIONS ARE MANUAL PULL STATION **AUTONOMOUS CONTROL UNIT** SMOKE DETECTOR PERMITTED [UFC 3-600-01, 4-2.3.3.3] ACU AUTOMATIC SPRINKLER FLOW SWITCH FIRE ALARM CONTROL PANEL SPRINKLER WATERFLOW INFORMATION PROVIDED IS FOR BIDDING NOTIFICATION APPLIANCE CIRCUIT PANEL FACP FIRE EXTINGUISHER CABINET PURPOSES ONLY, CONTRACTOR SHALL SECURE OR PERFORM AUTOMATIC SPRINKLER SYSTEM TAMPER SWITCH WATERFLOW TEST DATA TAKEN FROM FIRE HYDRANTS NEAREST FEC FIRE PUMP FACU CIRCUIT FAULT (OPEN, GROUND, SHORT) TO THE SITE FOR USE IN HYDRAULIC CALCULATIONS. FIRE EXTINGUISHER CABINET FP FLOW SWITCH COORDINATE WITH ANY EXISTING OR NEW MECHANICAL SMOKE DETECTOR PLUMBING, ELECTRICAL AND STRUCTURAL DRAWINGS TO AVOID FS ORDINARY HAZARD GROUP 1 CLASSIFICATION FIRE STAND PIPE OTHER TROUBLE CONDITION CONFLICTS OF THE NEW SYSTEM. FSP 8. ALL AUTOMATIC SPRINKLER HEADS, PIPE FITTINGS, HANGARS FIRE HOSE VALVE PRIMARY AC POWER LOSS MASS NOTIFICATION TEXT SIGN CONTROL VALVES AND MANUAL CONTROL VALVES SHALL BARE FHV ZONE CONTROL ASSEMBLY DUCT SMOKE DETECTOR THE FACTORY MUTUAL OR UNDERWRITER'S LABORATORY **EGRESS CAPACITY** ZCA APPROVAL AND BE APPROVED BY THE NAVFAC TECHNICAL **GALLONS PER MINUTE** FIRE PUMP RUNNING REPRESENTATIVE. GPM MASS NOTIFICATION SYSTEM MASS NOTIFICATION INPUT ALL PIPING SHALL BE MINIMUM SCHEDULE 40. REDUCTION TO SPRINKLER PIPE AND HEAD TO BE REMOVED MNS SCHEDULE 10 IS NOT PERMITTED REGARDLESS OF WHETHER POUNDS PER SQUARE INCH ACU EMERGENCY LIVE PAGING WATER QUALITY EVALUATION SUPPORTS THE OPTION. [UFC TRAVEL PATH & DISTANCE PSI SIGNALING LINE CIRCUIT 3-600-01, 4-2.3.2] ACU EMERGENCY PRE-RECORDED MESSAGE SELECT SLC 10. PROVIDE AUXILIARY DRAINS FOR BELOW DUCT SPRINKLERS AND TAMPER SWITCH COMMON PATH OF TRAVEL ACU NON-EMERGENCY PRE-RECORDED MESSAGE SELECT OTHER TRAPPED SECTIONS. TS POUNDS PER SQUARE INCH 11. ALL SPRINKLER PIPING SHALL BE PAINTED RED. ACU PRE-RECORDED "ALL CLEAR" 1-HR RATED FIRE BARRIER WIDE AREA MNS NON-EMERGENCY MESSAGE BROADCAST SPRINKLER HYDRAULIC INFORMATION 2-HR RATED FIRE BARRIER WIDE AREA MNS EMERGENCY MESSAGE BROADCAST NON-EMERGENCY LIVE PAGING EXISTING FLOW SWITCH TO REMAIN WATER SUPPLY INFORMATION DOD TELEPHONE SYSTEM NON-EMERGENCY PAGING STATIC (PSI): EXISTING TAMPER SWITCH TO REMAIN RESIDUAL (PSI): GENERAL: CONTRACTORS SHALL BE RESPONSIBLE TO ENSURE MNS AND FA PRIORITIES ARE PROGRAMMED IN ACCORDANCE WITH FIRE MARSHALL GUIDELINES. FLOW (GPM): EMERGENCY MNS MESSAGES (LIVE & PRE-RECORDED) SHALL TEMPORARILY OVERRIDE FIRE ALARM AUDIBLE EVACUATION AND DISABLE STROBES. EXISTING INSPECTORS TEST AND DRAIN DATE OF TEST: -PRE-RECORDED MNS MESSAGES SHALL REPEAT FOR 10 MINS OR UNTIL MANUALLY RESET. LOCATION OF TEST EXISTING RISER TO REMAIN PERFORMED BY: "ANNOUNCEMENT" MESSAGE ON TEXT SIGNS SHALL STAY ILLUMINATED FOR 10 SEC BEYOND THE END OF THE MESSAGE. EXISTING ZONE CONTROL ASSEMBLY TO REMAIN SUPERVISORY CONDITION ONLY OCCURS WHEN MNS SYSTEM IS OVERRIDING FIRE ALARM EVACUATION (ALARM CONDITION). ACTIVATION OF DUCT SMOKE DETECTOR SHALL SHUNT TRIP THE FAN MOTOR UNIT OF ANY ASSOCIATED AIR HANDLING UNIT FIRE SPRINKLER CONCEPTUAL RISER DIAGRAM **GENERAL NOTES** HAZARDOUS MATERIALS ARE PRESENT IN PROJECT SCOPE. REFER SPECIFICATIONS DIVISION 02 FOR DIRECTION ON ABATEMENT, CONTAINMENT AND DISPOSAL REQUIREMENTS APPROXIMATED PIPE FITTINGS BOTH SPRINKLER AND FIRE ALARM SYSTEMS ARE NOT PERMITTED TO HAVE AN OUTAGE FOR MORE THAN AN HOUR BEFORE STARTING WORK. THE FIRE ALARM AND SPRINKLER SYSTEM SHALL BE RESTORED WITHIN AN HOUR OF COMPLETION OF WORK. THE CONTRACTOR CANNOT LEAVE THE CONSTRUCTION SITE UNPROTECTED. THE SPRINKLER SYSTEM SHALL BE FILLED WITHIN AN HOUR OF COMPLETION OF WORK. 6" FSP-5 TEE, TEE THE FIRE ALARM CONTRACTOR IS RESPONSIBLE FOR TESTING ALL MODIFICATIONS TO THE FIRE ALARM SYSTEM. "FSP-10 EL, TEE " FSP-9 EL, TEE, 45E, 45E, EL ALL REQUIRED OUTAGES OF THE SPRINKLER AND FIRE ALARM SYSTEM SHALL BE COORDINATED THROUGH THE CONTRACTING OFFICER NOT LESS THAN 15 WORKING DAYS IN ADVANCE. THE GOVERNMENT WILL PROVIDE THE REQUESTED FSP-5 EL, EL, EL OUTAGE AND ASSOCIATED RESTORATION OF SPRINKLER OR FIRE ALARM SYSTEM. THE GOVERNMENT WILL IDENTIFY TO THE CONTRACTOR WHAT PIPING/CIRCUITS HAVE BEEN TAKEN OUT OF SERVICE ONCE THE OUTAGE HAS BEEN MADE. 'FSP-10 EL, EL. EL THE GOVERNMENT WILL NOT DRAIN OR REFILL SPRINKLER PIPING AS PART OF AN OUTAGE. THIS WORK SHALL BE PERFORMED BY THE CONTRACTOR. OUTAGES DO NOT INCLUDE CONNECTION OF NEW WORK TO EXISTING SPRINKLER PIPING, "FSP-9 EL, EL CONNECTION OF NEW FIRE ALARM DEVICES, AND/OR WIRING TO EXISTING SYSTEMS, OR PROGRAMMING CHANGES NECESSARY TO ACCOMMODATE NEW WORK THE CONTRACTOR AND HIS SUBCONTRACTORS ARE PRESUMED TO HAVE INSPECTED THE SITE AND TO BE FAMILIAR WITH THE CONTRACT DOCUMENTS AND ALL APPLICABLE REQUIREMENTS AND CONDITIONS AFFECTING THE PROJECT. FAILURE TO INSPECT THE SITE OR TO FULLY EXAMINE THE CONTRACT DOCUMENTS WILL NOT RELIEVE THE CONTRACTOR FROM ANY OBLIGATION RELATED TO THIS WORK. MATERIALS AND WORKMANSHIP SHALL CONFORM TO APPLICABLE REQUIREMENTS OF THE INTERNATIONAL BUILDING CODE (IBC), NATIONAL FIRE PROTECTION ASSOCIATION (NFPA),) AND ANY REGULATIONS OF FEDERAL, STATE OR LOCAL AGENCIES HAVING JURISDICTION. THE CONTRACTOR SHALL NOTIFY THE CONTRACTING OFFICERS TECHNICAL REPRESENTATIVE (COTR) IF ANY ISSUES ARISE REGARDING COMPLIANCE WITH APPLICABLE CODES AND REGULATIONS. A FIRE WATCH, AT CONTRACTOR'S COST, WILL BE CONDUCTED CONTINUOUSLY THROUGHOUT THE DURATION OF THE OUTAGE IN ALL AREAS AFFECTED BY THE OUTAGE. FINDINGS/COMMENTS WILL BE DOCUMENTED HOURLY ON FIRE WATCH FORMS PROVIDED BY THE VAMC FIRE PREVENTION DIVISION. DOCUMENTATION OF FINDINGS WILL BE MADE AVAILABLE TO THE VAMC FIRE DEPARTMENT OFFICIALS UPON THEIR REQUEST. IN THE EVENT OF ANY FIRE/SMOKE EMERGENCIES DISCOVERED DURING THE FIRE WATCH, EMERGENCY NOTIFICATION WILL BE CONDUCTED IN ACCORDANCE WITH PROCEDURES PROVIDED BY THE COTR OVERNIGHT OUTAGES WILL NOT BE PERMITTED UNLESS WORK IS BEING DONE DURING THAT TIME PERIOD AND THE SPRINKLER/FIRE ALARM SYSTEM IS PUT BACK INTO SERVICE WITHIN AN HOUR FROM COMPLETION OF WORK. OUTAGES SHALL BE LIMITED TO 8 HOURS INCLUDING TIME FOR DRAINING AND REFILLING. FIRESTOPPING OF FIRE-RATED WALLS AND PARTITIONS: FOR ALL RATED WALLS SHOWN IN THE DESIGN AREA, ALL EXISTING AND NEW WALL PENETRATIONS OF RATED BARRIERS SHALL BE FIRESTOPPED WITH A FIRESTOPPING SYSTEM HAVING A FIRE RESISTIVE RATING MATCHING THAT OF THE BARRIER PENETRATED. Project Number ARCHITECTS CONSULTANTS Office of Building 313B - Daycare Renovation Cover Sheet - Fire Protection 613-13-126 Construction Abbreviations, Legends & Symbols **Building Number** and Facilities 313B Approved: Project Director Drawing Number Management VAMC, Martinsburg, WV Department of Veterans Affairs Checked Drawn 04-23-2014 Author

